

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE
REQUIREMENTS FOR ELECTRICAL INSTALLATIONS - BS7671 [IEE WIRING REGULATIONS]

To be used for minor electrical work which does not include the provision of a new circuit.

PART 1: Description of the minor works

1. *Description of the minor works:* Replacement oi single socket outlet with a twin
2. *Location/address:* 12 Higher Mead road, COULSDON, CR5 9LT
3. *Date minor works completed:* 24 Feb 2003
4. *Details of departures, if any from BS7671: 2001 (as amended):*
None

PART 2: Installation details

1. *System earthing arrangement (where known):* TN-S
2. *Method of protection against indirect contact:*
Earthed equipotential bonding and automatic disconnection of supply
3. *Protective device for the modified circuit:* Type BS BS 1361 -
Rating 60 A
4. *Comments on existing installation, including adequacy of earthing and bonding arrangements:*
Good condition

PART 3: Essential tests

1. *Earth continuity:* Satisfactory
2. *Insulation resistance:*
Phase/neutral: >20 Mohms
Phase/earth: >20 Mohms
Neutral/earth: >20 Mohms
3. *Earth fault loop impednace:* 0.83 ohms
4. *Polarity:* Satisfactory
5. *RCD operation (if applicable):*
Rated residual operating current: N/A mA
Operating time: N/A ms

PART 4: Declaration

1. I/we CERTIFY that the said works do not impair the safety of the existing installation, that the said works have been designed, constructed, inspected and tested in accordance with BS7671: 2001 (IEE Wiring Regulations) amended to and that the said works, to the best of my/our knowledge and belief, at the time of my/our inspection, complied with BS7671: 2001 except as detailed in Part 1.
2. Name:
Position: Test engineer
For and on behalf of: Custom Maintenance Systems
Unit 27
Lewes Road Industrial Estate
BRIGHTON
BN71 3XY
Phone: 01473 4141410
NICEIC Enrolment No: 414141: NICEIC Branch Number: 301

Signed Date

CERTIFICATE No: MW035

MINOR ELECTRICAL INSTALLATION WORKS CERTIFICATE

GUIDANCE FOR RECIPIENTS

This Certificate has been issued to confirm that the electrical installation work to which it relates has been designed, constructed and inspected and tested in accordance with British Standard BS7671 (The IEE Wiring Regulations).

You should have received an original Certificate and the contractor should have retained a duplicate. If you were the person ordering the the work, but not the user of the installation, you should pass this Certificate, or a copy of it, to the owner.

The Minor Works Certificate is only to be used for additions, alterations or replacements to an installation that do not extend to the provision of a new circuit. Examples include the addition of a socket-outlet or lighting point to an existing circuit, or the replacement or relocation of a light switch.

A separate Certificate should have been received for each existing circuit on which minor works have been carried out. This Certificate is not valid if you requested the contractor to undertake more extensive installation work. An Electrical Completion Certificate would be required in such circumstances.

The original Certificate should be retained in a safe place and be shown to any person inspecting or undertaking further work on the electrical installation in the future. If you later vacate the property, this Certificate will demonstrate to the new owner that the minor electrical installation work complied with the requirements of British Standard 7671 at the time the certificate was issued.